

COPY OF BUILDING SAFETY CERTIFICATE

ਵਲੋਂ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।

ਵਲ

ਪ੍ਰਿੰਸੀਪਲ,
ਨਵਦੀਪ ਪਬਲਿਕ ਸਕੂਲ,
ਮੂਣਕ ਜਿਲ੍ਹਾ ਸੰਗਰੂਰ।

ਨੰ: 16 ਮਿਤੀ: 20-04-23

ਵਿਸ਼ਾ:- ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਲੈਣ ਸਬੰਧੀ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਸਬੰਧੀ ਆਪ ਦੀ ਮੰਗ ਅਨੁਸਾਰ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸਬੰਧੀ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਨਿਰਧਾਰਿਤ ਪ੍ਰੋਫਾਰਮੇ ਤੇ ਆਪ ਨੂੰ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ। ਲੋੜੀਂਦੀ ਫੀਸ ਜੀ. ਆਰ. ਨੰ: 665523 ਮਿਤੀ 18-04-2023 ਰਾਹੀਂ ਬਾਬਤ ਰਕਮ 50000/- ਰੁਪਏ ਪ੍ਰਾਪਤ ਕੀਤੀ।

ਨੋਟ/ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।


ਪਿੱਠ ਅੰਕਣ ਨੰ:

ਮਿਤੀ:-

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਸੰਗਰੂਰ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ: 278 ਮਿਤੀ 18-04-2023 ਦੇ ਸਬੰਧ ਵਿਚ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਲਹਿਰਾਗਾਗਾ।


Principal
Navdeep Public Sr. Sec. School
Moonak (Sangrur) Pb.
Affiliated to CBSE New Delhi
Affi. No. 1631339


Chairman
Navdeep Public Sr. Sec. School
Moonak (Sangrur) Pb.
Affiliated to CBSE New Delhi
Affi. No. 1631339


Building Safety Report


Name of School:- Navdeep Public Senior Secondary School, Tehsil Moonak District Sangrur

I have visited the above mentioned school building along with Sh Maninder Pal JE on 19.04.2023 and have visually inspected. It seems visually safe subject to the following observation & conditions.

- a) Parameters to check the stability and safety of building such as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications. Test Reports of Material used Quality Control reports and certificate from Engineer in Charge for construction are not available.
- b) In case of any addition, alteration or expansions and modification to this building are done; certificate may be re-obtained after completion from undersigned.
- c) In case the building is affected by flood or if there is settlement of walls/ foundation or sagging of roofs etc., immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent authority.
- e) A separate certificate regard Electrical Works should be obtained from the competent authority.
- f) The owner of the building/ Management is fully responsible regarding safety of building from all angels in spite of this report.
- g) The covered area of the building is 28255 SqFt.
- h) This Report is not valid for legal purpose.
- i) This building visually seems safe to occupy for the normal use up to: 31-03-2028
- j) The Building Certificate should not be considered as NOC for Road Access which will be taken separately by School as per Government policy No. 05/13/2018-3BR3/1294287/3 dated 10-08-2018.


Principal
Navdeep Public Sr. Sec. School
Moonak (Sangrur) Pb.
Affiliated to CBSE New Delhi
Affi. No. 1631339


Chairman
Navdeep Public Sr. Sec. School
Moonak (Sangrur) Pb.
Affiliated to CBSE New Delhi
Affi. No. 1631339


Sub-Divisional Engineer
Const. Sub-Dyn. PWD B&R
Lehragaga 